


KEY:

- SITE BOUNDARY (2.01 Hectares)
- 3.40m HIGH ELECTRIC PALISADE FENCING
- ▨ BATTERY (12.9m x 2.44 x 2.59m)
- ▨ INVERTER (6.1m x 2.44m x 2.59m)
- TRANSFORMER
- LV SWITCH HOUSE (12.9m x 2.44m x 3.0m)
- ▨ E-HOUSE (ENCLOSED IN BUILDING 20.7m x 36.7m x 10.0m TO ROOF PITCH)
- COOLER (9.6m x 2.4m x 2.5m)
- ▨ PROPOSED TRACK AREAS
- ▨ ENERGY MANAGEMENT SYSTEM (ENCLOSED IN BUILDING 20.7m x 38.6m x 10.0m TO ROOF PITCH)
- EMERGENCY DIESEL GENERATOR (6.0m x 6.0m)
- COMMS HOUSE (12.19m x 2.44m x 2.59m)
- BUILDING (20.7m x 38.6m x 10.0m TO ROOF PITCH)
- 10m HIGH FIRE STOP WALL
- 6m SECURITY COLUMN
- 4m HIGH WALL
- ▨ INDICATIVE EXISTING VEGETATION
- 13kV REACTOR
- ▨ INDICATIVE SWALE
- TRANSFORMER (3.0m x 3.0m)
- ▨ FLOOD RISK ZONE
- ▨ 15m BUFFER FROM ANCIENT WOODLAND AREA
- ▨ SWITCHGEAR CONTAINER (12.2m x 2.44m x 3.0m)
- WELFARE FACILITIES (12.9 x 2.44m x 2.59m)

LOCATION OF EXISTING AGRICULTURAL FIELD GATE (SHOWN SOLID BLACK) TO BE REMOVED AND REPLACED BY NEW AGRICULTURAL FIELD GATE (SHOWN DASHED BLUE) APPROXIMATELY 70m NORTH ALONG TRACK. THIS ALLOWS FOR UP TO 3 NO. UK MAX LENGTH ARTICULATED VEHICLES TO TURN OFF POTMAN'S LANE WHEN ENTERING THE SITE. EXISTING POST AND WIRE FENCE SHOWN DASHED BLACK.



Plot Date : 11 February 2021 13:28:09
File Name P:\PROJECTS\3215 NINFIELD\CAD\01-WORKING\01_01-DRAWINGS\3215-DR-P-0001-P10

Project Title NINFIELD BATTERY STORAGE SITE	Drawing Title FIGURE 2 PRE-APPLICATION PROPOSED SITE LAYOUT	Purpose of issue PRELIMINARY	THIS DOCUMENT HAS BEEN PREPARED IN ACCORDANCE WITH THE SCOPE OF ARCUS' APPOINTMENT WITH ITS CLIENT AND IS SUBJECT TO THE TERMS OF THAT APPOINTMENT. ARCUS ACCEPTS NO LIABILITY FOR ANY USE OF THIS DOCUMENT OTHER THAN BY ITS CLIENT AND ONLY FOR THE PURPOSES FOR WHICH IT WAS PREPARED AND PROVIDED	Arcus Consultancy Services 7th Floor 144 West George Street Glasgow, G2 2HG Tel: +44 (0)141 221 9997 Fax: +44 (0)141 221 5610 www.arcusconsulting.co.uk
Client 	Designed KB Drawn KB Checked DB Approved AM Date 11.02.21	Arcus Internal Project No. 3215 Scale @ A3 1:2500	Drawing Number 3215-DR-P-0001	Rev 10

