


- KEY:**
- SITE BOUNDARY (5.53 Hectares)
 - 2.40m HIGH WELDMESH FENCING
 - BATTERY (12.9m x 2.44 x 2.59m)
 - INVERTER (6.1m x 2.44m x 2.59m)
 - TRANSFORMER
 - LV SWITCH HOUSE (12.9m x 2.44m x 3.0m)
 - E-HOUSE (ENCLOSED IN BUILDING 20.7m x 36.7m x 10.0m TO ROOF PITCH)
 - COOLER (9.6m x 2.4m x 2.5m)
 - PROPOSED TRACK AREAS
 - MAIN CONTROL ROOM (6.1m x 2.44m x 3.0m)
 - ENERGY MANAGEMENT SYSTEM (ENCLOSED IN BUILDING 20.7m x 38.6m x 10.0m TO ROOF PITCH)
 - EMERGENCY DIESEL GENERATOR (6.0m x 6.0m)
 - BUILDING (20.7m x 38.6m x 10.0m TO ROOF PITCH)
 - SWITCHGEAR CONTAINER (12.2m x 2.44m x 3.0m)
 - TEMPORARY LAYDOWN
 - FIRE STOP WALL (36.2m X 0.4m x 10.0m)
 - ABERGELLI CORRIDOR
 - 6m SECURITY COLUMN
 - 4m HIGH WALL



Plot Date : 23 June 2020 11:37:33
 File Name P:\PROJECTS\3421 SWANSEA NORTH\CAD\01-WORKING\01_01-DRAWINGS\PLANNING FIGURES\3421-DR-P-0001B-P9

Project Title SWANSEA NORTH ENERGY MANAGEMENT FACILITY	Drawing Title PLANNING DRAWING 003A PROPOSED SITE LAYOUT MAIN COMPOUND	Purpose of issue PLANNING	THIS DOCUMENT HAS BEEN PREPARED IN ACCORDANCE WITH THE SCOPE OF ARCUS' APPOINTMENT WITH ITS CLIENT AND IS SUBJECT TO THE TERMS OF THAT APPOINTMENT. ARCUS ACCEPTS NO LIABILITY FOR ANY USE OF THIS DOCUMENT OTHER THAN BY ITS CLIENT AND ONLY FOR THE PURPOSES FOR WHICH IT WAS PREPARED AND PROVIDED	Arcus Consultancy Services 7th Floor 144 West George Street Glasgow, G2 2HG Tel: +44 (0)141 221 9997 Fax: +44 (0)141 221 5610 www.arcusconsulting.co.uk															
Client 	Arcus Internal Project No. 3421 Scale @ A3 1:1000	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Designed</td> <td>Drawn</td> <td>Checked</td> <td>Approved</td> </tr> <tr> <td>-</td> <td>KB</td> <td>DB</td> <td>AM</td> </tr> <tr> <td colspan="2">Date</td> <td colspan="2">15/04/20</td> </tr> </table>	Designed	Drawn	Checked	Approved	-	KB	DB	AM	Date		15/04/20		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>Drawing Number</td> <td>Rev</td> </tr> <tr> <td>3421-DR-P-0001A</td> <td>8</td> </tr> </table>	Drawing Number	Rev	3421-DR-P-0001A	8
Designed	Drawn	Checked	Approved																
-	KB	DB	AM																
Date		15/04/20																	
Drawing Number	Rev																		
3421-DR-P-0001A	8																		

